Ceiling Finishes

Description:

The purpose of the section is to highlight the current applicable UMCP Design Standards for the design and selection of interior ceiling finishes.

Related Sections:

• TBD

Effective Date:

• July 10, 2009

Applicable Standards:

• TBD

General Requirements:

- Acoustical 2' x 2' lay-in ceiling tiles shall be specified for all interior areas with the exception of restrooms, special use or public spaces.
- Acoustical ceiling tile shall have the following characteristics:
 - Materials: Mineral fiber ceiling panel
 - Size: 24" x 24" x 5/8"
 - Style: Lay-in, non-directional fissured pattern, square edge
 - Color: White
 - ASTM E 84 compliance: Class A ; flame spread: 25; smoke developed : 10
 - Noise Reduction Coefficient (NRC): 50 (minimum)
 - Ceiling Attenuation Class (CAC): 30 (minimum)
 - Recycled Content: 20% (minimum)